

**Summer Schedule
Facilities OPS Matrix**

Campus: University Park

6/11/2008

Rev. 13

Building	75°	80°	Manual	Auto	Locked (a)	Current Status	Average KW Per Month
SAACS		X	X			Phase Down	4431
Baseball Stadium		X	X			Fully Operational	31,160
Children's Center	X		X			Fully Operational	
College of Health		X	X			Fully Operational =IT	6,153
CBC	X			X		Bldg. A 1st Floor; Bldg. B 2nd Floor, Bldg. C & D 1st & 2nd Floor, All remaining -Phase Down Sat. at 5pm	110,294
CP	X			X		225,238,224,283,283B,3rd Floor =IT Fully Operational	286,473
CSC		X		X	X	Phase Down	137,541
CU (Z)		X	X		X	Phase Down	2,192,036
Business Services		X	X		X	Phase Down (Offices)	26,280
DM *	X	X		X	X	1st & 2nd - On / 3rd & 4th Partial Phase Down 409	163,484
ECS	X			X		202,204,210,258,265,232 (1&2)=IT 3rd & 4th Phase Down	199,818
Everglades Hall		X		X	X	Fully Operational	114,818
Football						N/A	not in use
GC	X			X		Fully Operational	388,916
Greek Housing							
GL	X	X		X	X	178, 1st Floor=IT A/C Schedule will follow LTG Schedule	466,924
Pharmed *	X	X		X		Offices Phase Down/ Training Fac. Fully Operational	171,018
HLS I	X			X		Fully Operational	178,581
HLS II	X			X		Fully Operational	17,236
EL 1	X	X	X			Fully Operational Saturday after 3pm Phase Down	28,527
Lakeview Housing	X			X		Fully Operational	236,987
MARC		X		X	X	Phase Down Need Spc. Event Schedule = Pavilion 6/13; Classrooms 6/27-7/11 until 3pm	84,098
OE	X			X		Fully Operational	253,709
PC *	X	X				Phase Down Misc. needs 3rd floor 435,434A (3rd & 4th) (6/13 1st & 2nd)=IT	407,746
Architecture		X		X	X	170=IT Phase Down	68,836
Garages		X			X	Phase Down	140,935
Panther Hall	X			X		Fully Operational	119,638
Frost Art	X			X	X	Fully Operational 24/7	40,500
RB	X			X		109A,150, 378=IT / 2nd & 3rd Phase Down	88,032
Law School		X		X	X	Phase Down 2nd Floor operational until Saturday at 5pm Note: 6/14, Atrium, 1st & 2nd floors running Saturday 9AM-2PM	199,810
Rec Center	X			X		Fully Operational	112,109

* Partial Operation - By Floors

(a) Building will be locked automatically or manually by Public Safety. For access, department must provide authorized access list to Public Safety and Facilities 48 hours in advance.

Legend:	
75°	Normal temperature setpoint
80°	Phase Down setpoint
Manual	Utilities personnel adjust temperature
Auto	Computer controlled temperature settings
Locked	Manually locked by Public Safety or Computer controlled by Key Control

